



Recognized by Pollution Control Board, Assam

NABL ACCREDITED

Certificate No. TC-7669

TEST REPORT:

Report No: 200921_1502091_0
 Sample ID No: EETNE/Sept/04/20
 Test Starting Date: 16/09/20

Date of Report: 21/09/20
 Date of sample receipt: 16/09/20
 Test completion Date: 21/09/20


Name & Address of Client	M/s. Raksha Cements Pvt. Ltd. Vill- Kamarkuchi, PO-Tapesia, Dist-Kamrup, Pin-782402, Assam.				
Sample Description	Type: Waste Water			Source: ETP Outlet	
Sample collected by	M/s. En-vision Enviro Technologies North East				
Sample Collection Particulars	Date 16/09/2020	Time 10:45 A.M	Temperature 30°C	Quantity Drawn:2L	Sampling Method :EETNE/SOP/02


SN	Parameter	Unit	Result	Method Followed by	Permissible Limit (CPCB)
1	p ^H	---	7.21	IS 3025(Part 11)1983(Reaffirmed 1996)	5.5-9.0
2	BOD	mg/L	15	APHA 23 rd Edition,5210B,Page:5-6	30
3	COD	mg/L	46	APHA 23 rd Edition,5220 b,Page:5-18	250
4	Oil & Grease	mg/L	1.6	IS 3025(Part 39)1991(Reaffirmed 2003)	10
5	Total Suspended Solids	mg/L	84.3	IS 3025(Part 18)1984(Reaffirmed 2012)	100

NOTE: (BOD) Biochemical Oxygen Demand, (COD) Chemical Oxygen Demand.

Comments: All the tested parameters are within the acceptable limit.

For Envision Enviro Technologies North East


Rimpi Sarma
 Environmental Chemist
 Test Done By


Dr. Pranita Chakraborty
 Quality Manager
 Authorized Signatory

Note: i) The results relate only to the parameters tested.
 ii) The test report shall not be reproduced except in full, without written approval of laboratory

End of Report