



TEST REPORT:

Report No: 230922_1502091_0
Sample ID No: EETNE/SEPT/12_A/23
Test Starting Date: 11/09/23

Date of Report: 22/09/23
Date of sample receipt: 09/09/23
Test completion Date: 16/09/23

Name & Address of Client	M/s. Raksha Cement Pvt. Ltd. Vill: Kamarkuchi, P.O- Tapesia, Dist- Kamrup, Pin- 782402, Assam.				
Sample Description	Type: ETP Waste Water			Source: ETP (Outlet)	
Sample collected by	M/s. En-vision Enviro Technologies North East				
Sample Collection Particulars	Date 09/09/23	Time 12:55 P.M	Temperature 31° C	Quantity Drawn: 2 Ltr	Sampling Method: EETNE/SOP/02

SL.No.	Parameter	Unit	Result	Method Followed by	Permissible limit (CPCB)
1	p ^H		7.82	IS 3025 (Part 11) 1983 (Reaffirmed 1996)	5.5 – 9.0
2	BOD	mg/l	16	APHA 23 rd Edition, 5210B, Page: 5-6	30
3	COD	mg/l	53	APHA 23 rd Edition, 5220B, Page: 5-18	250
4	Oil & Grease	mg/l	<5	IS 3025 (Part 39) 1991 (Reaffirmed 2003)	10
5	TSS	mg/l	74.3	IS 3025 (Part 16) 1984 (Reaffirmed 2002)	100

NOTE: (BOD) Biochemical Oxygen Demand, (COD) Chemical Oxygen Demand, (TSS) Total Suspended Solid

For Envision Enviro Technologies North East, Guwahati

Khairul Islam

Khairul Islam Sheikh
Environmental Chemist
Test Done By



NOTE: i) The Result relate only to the parameters tested.
ii) The test report shall not be reproduced except in full without written approval of laboratory.

End of Report