



TC-7669

NABLACCREDITED**TEST REPORT:**

Report No: 240314_1502110_0

ULR No: TC7669240000000256F

Sample ID No: EETNE/MAR/05_A/24

Test Starting Date: 06/03/24

Date of Report: 14/03/24

Date of sample receipt: 06/03/24

Test completion Date: 14/03/24

Name & Address of Client	M/s. Raksha Cement Pvt. Ltd. Vill: Kamarkuchi, P.O- Tapesia, Dist- Kamrup, Pin- 782402, Assam.				
Sample Description	Type: ETP Waste Water			Source: ETP (Outlet)	
Sample collected by	M/s. En-vision Enviro Technologies North East				
Sample Collection Particulars	Date 06/03/24	Time 10:35 A.M	Temperature 31° C	Quantity Drawn: 2 Ltr	Sampling Method: EETNE/SOP/02

SL.No	Parameter	Unit	Result	Method Followed by	Permissible limit (CPCB)
1	p ^H	----	7.14	IS 3025 (Part 11) 1983 (Reaffirmed 1996)	5.5 – 9.0
2	BOD	mg/l	12	APHA 23 rd Edition, 5210B, Page: 5-6	30
3	COD	mg/l	48	APHA 23 rd Edition, 5220B, Page: 5-18	250
4	Oil & Grease	mg/l	<5	IS 3025 (Part 39) 1991 (Reaffirmed 2003)	10
5	TSS	mg/l	71.8	IS 3025 (Part 18) 1984 (Reaffirmed 2002)	100

NOTE: (BOD) Biochemical Oxygen Demand, (COD) Chemical Oxygen Demand, (TSS) Total Suspended Solid

For Envision Enviro Technologies North East, Guwahati

Khairul Islam Sheikh
Environmental Chemist
Test Done By

Utpal Bezbaruah
Technical Manager
Reviewed by/Authorized Signatory

NOTE: i) The Result relate only to the parameters tested.

ii) The test report shall not be reproduced except in full without written approval of laboratory.

End of Report